

Wyniki - Nastawy

Typ	Numer		Pom.	Symbol	Nastawa	Aut.	dn	G	Kv	dP	Lokalizacja elementu		
	Pion	Dział.					[mm]	[kg/s]	[m3/h]	[Pa]			
Z	W	21	02	RTD-N-P	3.5	0.53	15	0.022	0.158	26793	Gałązka grzejnika	dn	15
Z	W	31	02	RTD-N-P	3.5	0.52	15	0.022	0.159	26467	Gałązka grzejnika	dn	15
Z	W	41	02	RTD-N-P	4	0.51	15	0.022	0.161	25607	Gałązka grzejnika	dn	15
Z	W	51	02	RTD-N-P	4	0.48	15	0.022	0.165	24473	Gałązka grzejnika	dn	15
Z	W	61	02	RTD-N-P	3	0.48	15	0.015	0.109	24068	Gałązka grzejnika	dn	15
Z	W	71	04	RTD-N-P	3	0.47	15	0.015	0.112	23669	Gałązka grzejnika	dn	15
Z	W	81	05	RTD-N-P	4	0.44	15	0.021	0.164	22149	Gałązka grzejnika	dn	15
Z	W	91	08	RTD-N-P	4	0.43	15	0.021	0.166	21591	Gałązka grzejnika	dn	15
Z	W	101	11	RTD-N-P	2.5	0.43	15	0.011	0.086	21664	Gałązka grzejnika	dn	15
Z	W	111	12	RTD-N-P	2	0.43	15	0.010	0.078	21640	Gałązka grzejnika	dn	15
Z	W	121	02	RTD-N-P	3.5	0.51	15	0.022	0.160	26033	Gałązka grzejnika	dn	15
Z	W	131	07	RTD-N-P	2.5	0.47	15	0.013	0.099	23660	Gałązka grzejnika	dn	15
Z	W	141	09	RTD-N-P	3	0.46	15	0.014	0.108	23092	Gałązka grzejnika	dn	15
Z	W	151	09	RTD-N-P	3	0.45	15	0.014	0.109	22727	Gałązka grzejnika	dn	15
Z	W	161	13	RTD-N-P	4	0.39	15	0.020	0.164	19759	Gałązka grzejnika	dn	15
Z	W	171	13	RTD-N-P	4	0.38	15	0.020	0.166	19401	Gałązka grzejnika	dn	15
Z	W	181	13	RTD-N-P	4	0.38	15	0.020	0.171	19266	Gałązka grzejnika	dn	15