

# Wyniki - Grzejniki podłogowe

Pom.	Fc	Lc	B	Tf	Qobl	Qwym	Qrz	Qdef	Agrz	dn	w	dP	tz	dt	AG	G
	[m2]	[m]	[m]	[°C]	[W]	[W]	[W]	[W]		[mm]	[m/s]	[Pa]	[°C]	[K]		[kg/s]
001	39.0	390.0	0.100	20.95	1766	1756	2018	-262	0.995	20	0.21	22020	39.97	12.03	1.00	0.04218
001	39.0	195.0	0.200	20.17	1876	1866	1673	193	0.994	20	0.22	12152	39.94	9.41	1.00	0.04481
001	39.0	390.0	0.100	21.00	1876	1866	2044	-178	0.995	20	0.22	24437	39.91	11.47	1.00	0.04481
001	39.0	195.0	0.200	20.12	1766	1756	1653	103	0.994	20	0.21	10951	39.96	9.88	1.00	0.04218
001	39.0	195.0	0.200	20.17	1876	1866	1672	194	0.994	20	0.22	12152	39.92	9.40	1.00	0.04481
001	39.0	390.0	0.100	21.00	1876	1866	2042	-176	0.995	20	0.22	24439	39.88	11.45	1.00	0.04481