

Wyniki - Nastawy

Typ	Numer		Pom.	Symbol	Nastawa	Aut.	dn	G	Kv	dP
	Pion	Dział.					[mm]	[kg/s]	[m3/h]	[Pa]
Z	W	31	09	RTD-N-P	3.5	0.54	15	0.016	0.157	14784
Z	W	41	09	RTD-N-P	3.5	0.52	15	0.016	0.154	14270
Z	W	42	09	RTD-N-P	3.5	0.52	15	0.016	0.154	14270
Z	W	51	10	RTD-N-P	4	0.55	15	0.020	0.188	15152
Z	W	61	10	RTD-N-P	4	0.51	15	0.020	0.195	14169
Z	W	71	06	RTD-N-P	4	0.50	15	0.019	0.189	13683
Z	W	81	06	RTD-N-P	4	0.47	15	0.019	0.194	13015
Z	W	111	03	RTD-N-P	3.5	0.40	15	0.014	0.151	11024
Z	W	121	05	RTD-N-P	5	0.39	15	0.023	0.255	10692
Z	W	131	05	RTD-N-P	5	0.38	15	0.023	0.257	10487
Z	W	141	04	RTD-N-P	4	0.44	15	0.017	0.176	12050
Z	W	151	04	RTD-N-P	4	0.37	15	0.017	0.192	10101
Z	W	161	02	RTD-N-P	4	0.35	15	0.014	0.165	9785
Z	W	171	01	RTD-N-P	4.5	0.35	15	0.018	0.219	9608
Z	W	181	01	RTD-N-P	4.5	0.34	15	0.018	0.220	9429